



Ref. Certif. No.

**BE-46701**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product

Rechargeable Li-ion Battery Distribution Unit

Name and address of the applicant

Zhejiang Hyxi Technology Co., Ltd.  
Floor 9-10, Building 3, Jiuyao Commercial Center, Zhuantang Street, Xihu District, Hangzhou, Zhejiang, China

Name and address of the manufacturer

Zhejiang Hyxi Technology Co., Ltd.  
Floor 9-10, Building 3, Jiuyao Commercial Center, Zhuantang Street, Xihu District, Hangzhou, Zhejiang, China

Name and address of the factory

Zhejiang LeapEnergy Technology Co., Ltd.  
No. 888 Xinrong Road, Sumeng Town, Wucheng District, Jinhua, Zhejiang, China.


Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

HYX-E50-H: 102,4 V, 52 Ah; HYX-E100-H: 204,8 V, 52 Ah;  
HYX-E150-H: 307,2 V, 52 Ah; HYX-E200-H: 409,6 V, 52 Ah

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

HYX-E50-H, HYX-E100-H, HYX-E150-H, HYX-E200-H

Additional information (if necessary may also be reported on page 2)

-  
 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62619:2022  
National Differences:

As shown in the Test Report Ref. No. which forms part of this Certificate

-  
SHES230701348601

This CB Test Certificate is issued by the National Certification Body

SGS Belgium NV - Division SGS CEBC  
Riverside Business Park  
Bld Internationalelaan 55, Building A  
B-1070 Brussels, Belgium



Date: 2023-11-30

Signature: Mark Lohmann